

Compliance with EN50549-1 (-2) statement

ComAp a.s. hereby declares that control units **InteliGen1000**, **InteliMains 1010**, **InteliSys GAS**, **InteliGen GSC(-C)**, **InteliSys GSC** and **InteliMains GSC** are fully in compliance with standard EN 50549-1 (-2) in the versions declared in the table below.

Control unit	Firmware version	Grid Codes module version
InteliSys GAS	Since version 1.9.0	1.2
InteliGen GSC(-C)	Since version 1.3.0	1.2
InteliSys GSC	Since version 1.3.0	1.2
InteliMains GSC	Since version 1.2.0	1.2
InteliGen 1000	Since version 2.2.0	1.3
InteliMains 1010	Since version 2.2.0	1.3

In Prague, 1st June 2022



Mrkvicka Lukáš

Product manager
Lukas.mrkvicka@comap-control.com